

MUNICIPALITY OF NORTH GRENVILLE

WATER SUMMARY REPORT

2008

Under the Safe Drinking Water Act 2002 - O-Reg 170/03 the Kemptville Well Supply (water works number 220001236) is classified as a Large Municipal System. The Act requires that as a large municipal system particular schedules of O-Reg 170/03 be followed. The following chart indicates the schedules that are to be followed:

Schedule Number	Description
Schedule 1	<p style="text-align: center;">Treatment Equipment</p> <ol style="list-style-type: none">1) Any raw water well is protected from any surface water or foreign debris entering the well.2) Water treatment equipment is in operation and operated in accordance with <i>The Procedures For Disinfection of Drinking Water in Ontario</i> when supplying water.3) The free chlorine residual never be less than 0.05 milligrams per litre in the drinking water system.
Schedule 4	Not Applicable
Schedule 6	<p style="text-align: center;">Operational Checks, Sampling and Testing - General</p> <ol style="list-style-type: none">1) All samples to be taken at the point where the water enters the drinking water system.2) A free chlorine sample is taken whenever a sample is tested for a microbiological parameter, except when the sample is raw water.3) All samples are to be grab samples unless continuous sampling equipment is used for free chlorine and turbidity.4) Continuous sampling equipment must meet minimum sampling requirements and record date, time, and location of sample.5) Results of continuous monitoring equipment must be examined by a certified operator within 72 hours of being taken.6) The continuous monitoring equipment must be capable of causing an alarm if any of the following conditions arise.<ol style="list-style-type: none">(a) power failure(b) equipment malfunction(c) a parameter above maximum standard(d) a parameter below minimum standard7) Continuous monitoring equipment must be cleaned and calibrated according to manufacturer's specifications.8) All samples taken to an accredited laboratory must be taken and handled according to the directions of the laboratory.9) Written notification must be submitted to the Director identifying the laboratory being used to test for a parameter.10) Add samples must show the date, time, location where the sample was taken and the name of the person who took the sample.

<p>Schedule 7</p>	<p style="text-align: center;">Operational Checks</p> <p>Chlorine Residual Free chlorine residual testing is to be done at or near a location where the contact time has been completed.</p> <p>Turbidity At least once a month a raw water sample must be tested.</p> <p>All sampling must be completed by a Certified Operator.</p>
<p>Schedule 10</p>	<p style="text-align: center;">Microbiological Sampling and Testing</p> <p>Distribution Samples If the system serves less than 100,000 people 8 distribution samples plus 1 additional sample for every 1000 people served by system Samples must be tested for Total Coliforms, E.Coli or Fecal Coliforms and at least 25 % for background (general bacteria)</p> <p>Treated Samples At least once a week a sample of treated water must be tested for Total Coliforms, E.Coli or Fecal Coliforms and general bacteria as Background or Heterotrophic plate counts.</p> <p>Raw Samples At least once a week a sample of raw water must be tested for Total Coliforms, E.Coli or Fecal Coliforms.</p>
<p>Schedule 13</p>	<p style="text-align: center;">Chemical Sampling and Testing</p> <p>Inorganics The owner shall ensure that at least one water sample is tested every 36 months, if the system obtains water from a raw water supply that is ground water. The owner shall ensure that all parameters in Schedule 23 are tested for.</p> <p>Lead The owner shall ensure a sample from a point in the distribution system where elevated concentrations of lead would be likely be taken every 12 months.</p> <p>Organics The owner shall ensure that at least one water sample is tested every 36 months, if the system obtains water from a raw water supply that is ground water. The owner shall ensure that all parameters in Schedule 24 are tested for.</p> <p>Trihalomethanes The owner shall ensure that at least one distribution sample is take every three months at a point in the distribution system where there is an elevated potential for the formation of trihalomethanes</p> <p>Nitrites and Nitrates The owner shall ensure that at least one sample is taken every three months and tested for Nitrites and Nitrates.</p> <p>Sodium The owner shall ensure that at least one sample is tested for sodium every 60 months.</p> <p>Fluoride The owner shall ensure that at least one sample is tested for fluoride every 60 months if the system does not provide fluoridation.</p>

<p>Schedule 15.2</p>	<p style="text-align: center;">Lead "NEW"</p> <p>Drinking water tests 15.1-8 Every test of a sample taken from plumbing under section 15.1-4 and 15.1-5 is prescribed as a drinking-water test for the purpose of the definition of "drinking-water test" in section 2 of the Act. Reporting requirements from samples taken from plumbing 15.1-9 1) If the operating authority for a drinking water system or the owner of a drinking water system receives a report of a test result for a test conducted on a sample taken from plumbing under section 15.1-4 or 15.1-5, the operating authority or owner shall, within seven days after receiving the report, give the following to the occupant or the premises served by the tap from which the sample was taken: 1. A copy of the report. 2. A statement of whether the report indicates a result that exceeds any schedule 2 standard. 3. If the report indicates a result described in paragraph 2, any advice given by the medical officer of health to the operating authority or owner with respect to any steps that the occupant should take. 4. The telephone number of a person who is available to answer questions about the report. Corrective action for adverse results 15.1-10 If a report is made under subsection 15.1-9 (2), the owner of the drinking water system and the operating authority for the system shall take such steps as are directed by the medical officer of health, including, if directed by the medical officer of health, providing information to occupants of the premises served by the plumbing from which the sample was taken that is in addition to the information provided under paragraph 3 of subsection 15.1-9 (1)</p>
<p>Schedule 16</p>	<p style="text-align: center;">Reporting Adverse Test Results and Other Problems</p> <p>Duty to Report 1) Any parameter that exceeds the standards prescribed by Schedule 1, 2 or 3 of the Ontario Drinking-Quality Standards other than fluoride. 2) Any result indicating the presence of Bacteria. 3) Any result indicating the presence of a pesticide not listed in Schedule 2 of the Ontario Drinking-Quality Standards at any concentration. 4) Any result indicating a free chlorine residual of less than 0.05 milligrams per litre if drinking water system provides chlorination. 5) Any result showing a concentration of greater than 20 milligrams per litre of sodium. 6) Any result showing a concentration of fluoride greater than 1.5 milligrams per litre if the drinking water system does not provide fluoridization</p> <p>Duty to Report Other Observations The owner of the system must report to the Ministry and the Medical Officer of Health any observations of drinking water being directed into the system that is not properly disinfected.</p> <p>Reporting When reporting any adverse water quality result or observation the proper protocol set out in O-Reg 170/03 must be followed.</p>

Corrective Action**Improper Disinfection**

If a report is required to be made under section 16-4 of schedule 16 the following action must be taken

- (a) the proper chlorine residual must be restored immediately.
- (b) any other steps as directed by the Medical Officer of Health.

Turbidity

If a report is required under section 18 of the Act the following corrective action must be taken.

- (a) check turbidity monitoring equipment and review operational procedures to identify the causes of problem.
- (b) any other steps as directed by the Medical Officer of Health.

Chlorine Residual

If a report is required under section 18 of the Act the following corrective action must be taken.

- (a) immediately increase the chlorine dose and flush the watermains to ensure that a free chlorine residual of 0.2 milligrams per litre is achieved in all parts of the affected distribution system.
- (b) any other steps as directed by the Medical Officer of Health.

E. Coli or Fecal, Total or Background Coliforms

If a report is required under section 18 of the Act the following corrective action must be taken.

- (a) immediately resample and test.
- (b) immediately increase the chlorine dose and flush the watermains to ensure that a free chlorine residual of 0.2 milligrams per litre is achieved in all parts of the affected distribution system.
- (c) maintain the free chlorine residual referred to in the above paragraph and resample until two consecutive samples taken 24 to 48 hours apart show no detected coliforms or as directed by the Medical Officer of Health.
- (d) any other steps as directed by the Medical Officer of Health.

Chemical, Radiological Parameters or a Pesticide not listed in Schedule 2 of O-Reg 169/03

If a report is required under section 18 of the Act the following corrective action must be taken.

- (a) immediately resample and test.
- (b) any other steps as directed by the Medical Officer of Health.

Health Related Parameters in an Approval or Order

If a report is required under section 18 of the Act as a result of an approval or order the following steps must be taken.

- (a) immediately resample and test.
- (b) any other steps as directed by the Medical Officer of Health.

Sodium

If a report is required under section 18 of the Act the following corrective action must be taken.

- (a) immediately resample and test.
- (b) if the concentration exceeds 20 milligrams per litre, take such steps as are directed by the Medical Officer of Health.

Schedule 20	<p style="text-align: center;">Engineers Report</p> <p>A report must be prepared by a professional engineer with experience in sanitary engineering every five years. The report must be prepared in accordance with <i>The Terms of Reference for Engineer's Reports for Water Works</i>, dated August 2000.</p>										
Schedule 22	<p style="text-align: center;">Summary Report</p> <p>The owner of a drinking water system shall ensure that, no later than March 31 of each year a report be presented to council which shall include the following requirements.</p> <p>(a) the report must list the requirements of the act, the system's approval and any order that the system failed to meet during the period covered by the report and corrective actions for each failure.</p> <p>(b) a summary report of flow rates with a comparison to the rated capacity and flow rates in the system's approval</p>										
Schedule 23	<p style="text-align: center;">Inorganics</p> <p>The list of inorganic parameters that are tested for:</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Antimony</td> <td style="width: 50%;">Arsenic</td> </tr> <tr> <td>Barium</td> <td>Boron</td> </tr> <tr> <td>Cadmium</td> <td>Chromium</td> </tr> <tr> <td>Mercury</td> <td>Selenium</td> </tr> <tr> <td>Uranium</td> <td></td> </tr> </table>	Antimony	Arsenic	Barium	Boron	Cadmium	Chromium	Mercury	Selenium	Uranium	
Antimony	Arsenic										
Barium	Boron										
Cadmium	Chromium										
Mercury	Selenium										
Uranium											
Schedule 24	<p style="text-align: center;">Organics</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%; vertical-align: top;"> Alachlor Aldrin-Dieldrin Azinphos-Methyl Benzene Bromoxynil Carbofuran Chlorodane (total) Cyanazine Dicamba 1,4-Dichlorobenzene 1,2-dichloroethane Dichloromethane Diclofop-methyl Dimethoate Diquat Glyphosate Lindane (Total) Methoxychlor Metribuzin Paraquat Pentachlorophenol Picloram Prometryne Temephos 2,3,4,6-Tetrachlorophenol Triallate 2,4,6-Trichlorophenol Trifluran </td> <td style="width: 50%; vertical-align: top;"> Aldicarb Atrazine+N-dealkylated metabolites Bendiocarb Benzo(a)pyrene Carbaryl Carbon Tetrochloride Chlorpyrifos Diazinon 1,2-Dichlorobenze Dichlorodiphenyltrichloroethane (DDT) metabolites 1,1-Dichloroethylene (vinylidene chloride) 2,4_Dichlorophenol 2,4-Dichlorophinoxy acetic acid (2,4D) Dinoseb Diuron Heptachlor+Heptachlor Epoxide Malathion Metolachlor Monochlorobenzene Parathion Phorate Polychlorinated Biphenyls (PCB) Simazine Terbufos Tetrachloroethylene (perchloroethylene) Trichloroethylene 2,4,5-Trichlorophenoxy acetic acid (2,4,5-T) Vinyl Chloride </td> </tr> </table>	Alachlor Aldrin-Dieldrin Azinphos-Methyl Benzene Bromoxynil Carbofuran Chlorodane (total) Cyanazine Dicamba 1,4-Dichlorobenzene 1,2-dichloroethane Dichloromethane Diclofop-methyl Dimethoate Diquat Glyphosate Lindane (Total) Methoxychlor Metribuzin Paraquat Pentachlorophenol Picloram Prometryne Temephos 2,3,4,6-Tetrachlorophenol Triallate 2,4,6-Trichlorophenol Trifluran	Aldicarb Atrazine+N-dealkylated metabolites Bendiocarb Benzo(a)pyrene Carbaryl Carbon Tetrochloride Chlorpyrifos Diazinon 1,2-Dichlorobenze Dichlorodiphenyltrichloroethane (DDT) metabolites 1,1-Dichloroethylene (vinylidene chloride) 2,4_Dichlorophenol 2,4-Dichlorophinoxy acetic acid (2,4D) Dinoseb Diuron Heptachlor+Heptachlor Epoxide Malathion Metolachlor Monochlorobenzene Parathion Phorate Polychlorinated Biphenyls (PCB) Simazine Terbufos Tetrachloroethylene (perchloroethylene) Trichloroethylene 2,4,5-Trichlorophenoxy acetic acid (2,4,5-T) Vinyl Chloride								
Alachlor Aldrin-Dieldrin Azinphos-Methyl Benzene Bromoxynil Carbofuran Chlorodane (total) Cyanazine Dicamba 1,4-Dichlorobenzene 1,2-dichloroethane Dichloromethane Diclofop-methyl Dimethoate Diquat Glyphosate Lindane (Total) Methoxychlor Metribuzin Paraquat Pentachlorophenol Picloram Prometryne Temephos 2,3,4,6-Tetrachlorophenol Triallate 2,4,6-Trichlorophenol Trifluran	Aldicarb Atrazine+N-dealkylated metabolites Bendiocarb Benzo(a)pyrene Carbaryl Carbon Tetrochloride Chlorpyrifos Diazinon 1,2-Dichlorobenze Dichlorodiphenyltrichloroethane (DDT) metabolites 1,1-Dichloroethylene (vinylidene chloride) 2,4_Dichlorophenol 2,4-Dichlorophinoxy acetic acid (2,4D) Dinoseb Diuron Heptachlor+Heptachlor Epoxide Malathion Metolachlor Monochlorobenzene Parathion Phorate Polychlorinated Biphenyls (PCB) Simazine Terbufos Tetrachloroethylene (perchloroethylene) Trichloroethylene 2,4,5-Trichlorophenoxy acetic acid (2,4,5-T) Vinyl Chloride										

NOTE: For a copy of O. Reg 170/03 contact the Water/Wastewater Department.

2008 FLOWS

Van Buren: Rated Flow: 1363 M³ or Day or 947 l/m

Month	Treated Flow M ³ /D	Raw Flow M ³ /D	% Difference	Instantaneous Treated Flow l/m *	Instantaneous Raw Flow l/m**	Average Flow M ³ /D
January	17642	18034	2.2	1143	1162	569.1
February	18350	18817	2.5	1040	1148	632.8
March	20222	20785	2.8	1166	1144	652.3
April	19394	20637	6.4	1027	1209	646.5
May	21112	21744	3.0	1166	1208	681
June	20154	20692	2.7	1111	1186	671.8
July	14615	16246	10	1111	1515	503.9
August	14924	15365	3.0	772	823	481.4
September	15014	15423	2.7	772	782	500.5
October	15115	16101	6.5	772	763	487.6
November	16165	16631	2.9	772	756	521.5
December	16542	17064	3.2	772	1052	533.6

* Large Instantaneous flows could be due to fire pump running.

** Initial flows are higher due to pump surge. Second value is flow after surge.

Alfred: Rated Flow: 2946 M³/Day or 2046 l/m

Month	Treated Flow M ³ /D	Raw Flow M ³ /D	% Difference	Instantaneous Treated Flow l/m *	Instantaneous Raw Flow l/m **	Average Flow M ³ /D
January	25704	26194	1.9	3056	1510	829.2
February	23404	23894	2.1	2886	1509	807.0
March	25992	26547	2.1	2935	2384	838.5
April	25268	25878	2	2925	1520	842.3
May	27045	27533	1.8	3311	1646	872.4
June	28705	29161	1.6	2517	2384	956.8
July	33748	34123	1.1	3786	1864	1124.9
August	16031	16257	1.4	2164	1287	517.1
September	14326	14596	1.9	1163	1131	477.5
October	17189	17450	1.5	2628	1204	554.5
November	20117	20517	2	2252	1577	670.6
December	20282	20624	1.7	2628	1577	654.3

* Large Instantaneous flows could be due to fire pump running.

** Initial flows are higher due to pump surge. Second value is flow after surge.

Kernahan: Rated Flow: 1964 M³/Day or 1364 l/m

Month	Treated Flow M ³ /D	Raw Flow M ³ /D	% Difference	Instantaneous Flow l/m *	Instantaneous Raw Flow l/m **	Average Flow M ³ /D
January	10536	10171	3.6	3645	888	339.9
February	6436	5991	6.1	3645	929	221.9
March	8759	8355	4.8	3645	929	282.5
April	11699	11161	4.8	3645	954	389.9
May	12788	12611	1.4	3645	938	412.5
June	9162	8548	7.2	3474	1210	305.4
July	4085	5654	38.4***	3474	1424	140.8
August	5900	5606	5.2	2411	962	190.3
September	6660	7198	8	1150	1051	222.0
October	7812	7512	2.7	2411	1051	235.9
November	6373	5705	1.7	1165	961	212.4
December	7270	6554	10.9	2411	1051	234.5

* Large Instantaneous flows could be due to fire pump running.

** Initial flows are higher due to pump surge. Second value is flow after surge.

*** Kernahan Pumping Station was shut down a portion of the summer for new construction and cleaning the old reservoir.

2008 Kemptville Well Supply

SUMMARY OF NON COMPLIANCE ISSUES AND ACTIONS REQUIRED

by the Ministry of Environment

Taken from Kemptville Well Supply Annual Inspection Report

Inspection Number: 1-60UUW

Date: August 26, 2008

Inspected By: Mary Wooding

NON-COMPLIANCE WITH REGULATORY REQUIREMENTS AND ACTIONS REQUIRED

This section provides a summary of all non-compliance with regulatory requirements identified during the inspection period, as well as actions required to address these issues. Further details pertaining to these items can be found in the body of the inspection report.

1. Records of flows and any capacity exceedences were not made in accordance with the Permit, Licence or Approval issued under Part V of the SDWA.

A review of the month end reports generated from the PLC/SCADA from October 1, 2007 until August 30, 2008, indicates frequent daily exceedences of the instantaneous rate of taking (L/Min). The issue of instantaneous flow rate exceedences has been addressed in annual inspection reports over the last several years.

In the event that flows are exceeded for extended periods of time, the length of the exceedence and the reason for the exceedence must be recorded. The operator's advised that the exceedences are generally related to pump start up; however, this is not consistently identified in the logbook.

It was noted that the operators do not highlight the peaks in data that are not true peaks as verified by trending by the SCADA system. It is recommended that the operators write, for example, "verified by trending not to be a true peak" on the daily review sheets and then record the actual value and/or circle the actual value on the daily review sheet. It is recommended that when operators conduct their reviews of flow data results, they review the peak raw water flow rates and record the details of any exceedences of the rated capacity in the WTP logbook or on the daily SCADA report and note the reason for the exceedence.

Action(s) Required:

By no later than December 31, 2008 the owner is required to provide the undersigned Provincial Officer with an action plan to describe in detail how the municipality intends to address this issue in the future. The municipality is required to ensure the 'true' maximum instantaneous flow rate is documented for each day with a note documenting the time, duration, and reason for the exceedence of the maximum instantaneous flow rate.

2. The operations and maintenance manuals did not meet the requirements of the Permit, Licence or Approval issued under Part V of the SDWA.

Condition 6.5 of the Certificate of Approval identifies that an up-to-date Operations Manual must be maintained and available for reference by all persons. The last two inspection reports have identified individual items that have not met the requirement as outlined in Condition 6.5 (i to ix). It is important to acknowledge the work being put into the new Operations Manual by the municipality however there are three requirements as outlined in the Certificate of Approval that the current Operations Manual does not meet.

(vi) procedures for the dealing with complaints related to the drinking-water system, including the recording of the nature of the complaint and any investigation and corrective action taken in respect of the complaint;

(viii), an inspection schedule for all wells associated with the water treatment system(s), including all above and below grade well components;

(ix) remedial action plans for situations where an inspection indicates non-compliance with respect to regulatory requirements and/or risk to raw well water quality.

Action(s) Required:

By no later than December 31, 2008, the owner is required to provide to the undersigned Provincial Officer a written procedure to address the three outstanding operations manual requirements that need to be addressed in order to bring the municipality into compliance with the Certificate of Approval, section 6.5 (i to ix).

This written procedure must include a written water system complaint procedure. The procedure should identify what steps need to be conducted before the complaint is considered successfully addressed. This may include what investigation and corrective action are required. Additionally, the procedure may also include completion of a complaint log, physical visit to the site of the complaint, list of municipal staff

that must be made aware of the complaint, if emergency services are required, a list of emergency contacts, a filing system to ensure that repeat complaints are addressed, etc.

The owner must also include a defined well inspection and maintenance procedure for each well (all above and below grade components). Lastly, the owner is required to produce a remedial action plan for situations where an inspection indicates non-compliance with respect to regulatory requirements and /or risk to raw well water quality.

3. **The owner had not developed a written contingency/emergency plan as required by the Permit, Licence or Approval issued under Part V of the SDWA.**

The emergency contingency plan is required as prescribed by section 6.5 of the current system Certificate of Approval. The municipality is currently working towards completion of a full scope of emergency/contingency plans to comply with the Drinking Water Quality Management Standard (DWQMS).

Action(s) Required:

This issue will be reviewed during the 2009-10 annual inspection of the drinking-water system.

4. **Operator certificates or water quality analyst certificates were not displayed in a conspicuous location at the workplace or at the premises from which the subsystem was managed.**

Action(s) Required:

By December 31, 2008 the municipality must respond in writing to the undersigned Provincial Officer to acknowledge that the operator certificates have been displayed in an appropriate location at the water pollution control plant.

5. **All sampling requirements for lead prescribed by schedule 15.1 of O. Reg. 170/03 were not met.**

A review of laboratory reports of analyses and a review of a summary spreadsheet for community Lead testing revealed that the municipality was not able to meet the required numbers of lead sample locations during the first round of testing (December 2007 to April 2008).

Action(s) Required:

By no later than December 31, 2008, the owner is required to provide to the undersigned Provincial Officer a written assurance that the municipality was able to secure the required number of sample points for each of the three required locations for the sample period June 15, 2008 to October 15, 2008.

6. **All changes to the system registration information were not provided within ten (10) days of the change.**

Mr. Gary Simser reviewed the drinking-water system profile and acknowledged there are required changes to the 7x24 Contact person details and the operator alternate contact information.

Action(s) Required:

By no later than December 31, 2008, the owner is required to make the necessary changes to the drinking water system profile in the ministry's Drinking Water Information System (DWIS). This is critical in the event of an adverse test result to ensure the proper contacts in the municipality are notified in a timely manner.

2008 Kemptville Well Supply

ACTIONS TAKEN BY THE NORTH GRENVILLE WATER DEPARTMENT

by North Grenville Staff

KEMPTVILLE WELL SUPPLY

Response to Drinking Water System Inspection Report.

DWS # 220001236

Inspection Number: 1-6OUUW

Date of Inspection: August 26, 2008

Date of Response: December 13, 2008

Response By: Gary Simser

Action #1

Condition: Exceedence's on Daily SCADA report.

A procedure has been entered into the North Grenville Environmental Services Operation/Contingency Plan on how exceedences which appear in the Daily SCADA logs are to be dealt with. Operators have been instructed that when reviewing the Daily SCADA report that any exceedences are to be entered into the operator comment section of the report and should list the time, duration and reason for the exceedence.

Action #2

Condition 6.5 (vi) of the Certificate of Approval procedures for dealing with complaints. A procedure has been entered into the operation/contingency plan on how complaints are to be dealt with. The procedures documents how complaints are to be logged, dealt with, and how the resolution to the complaint is to be logged.

Condition 6.5 (vii)(viii) of the Certificate of Approval to develop a well inspection procedure.

As stated in the 2007 inspection, the municipality had entered into talks with Lotowater Technical Services out of Paris Ontario as to the best way to get a well inspection procedure in place.

In March of 2008 Lotowater performed a series of tests on each of the wells to evaluate their performance. Using historical data and comparing it to present day data Lotowater provided a list of summary and recommendation list for each well (report follows). A secondary consultant (Golder Associates) was brought in to review Lotowater's findings. This fall Lotowater has been contracted to perform an in-depth investigation into each well and any deficiencies that should be dealt with. At the end of this period an inspection procedure will be developed using the data presented by Lotowater.

Condition 6.5 (ix) of the Certificate of Approval a remedial action plan where an inspection shows a non-compliance and/or risk to raw water quality.

A procedure has been entered into the operation/contingency manual on how any non-compliance issue and/or risk to the raw water quality is to be handled.

Action #3

Condition: development of a operation/emergency contingency plan as per Section 6.5 of the Certificate of Approval.

The plan is under development and will be reviewed as part of the 2009 inspection.

Action #4

Condition: Certificates not displayed.

A display case has been purchased and will be installed on the wall at the WWTP and all licences will be displayed in this case. (The case is presently on back order but will be installed as soon as we receive it.)

Action #5

Condition: Lead Sampling.

As noted by myself during the 2008 inspection the first round of lead testing left us short of volunteers. At that I didn't apply for relief from sampling. The second round of lead sampling went better and we received more volunteers than we required. We now have a list of volunteers that surpasses the numbers that we require so numbers of samples will not be a problem in the future.

This week we received a Certificate of Approval (PB220001236RR-01) Relief from Regulatory Requirements.

Action #6

Condition: Drinking Water System profile.

On December 1st I contacted the help line for DWS, left my name and that I needed to update our municipal system profile. On December 2nd I received a call from Gayathry Krishnakumar from the MOE. She forward the blank system profile update form to me. I filled in primary contact information and alternate contact information and emailed the form back. The profile should be up to date soon.

2008 Kemptville Well Supply

ADVERSE WATER QUALITY RESULTS AND ACTIONS TAKEN

Date	Indicator of Adverse Water Quality	Action Taken as Per the Medical Officer of Health	Result
January 02, 2008	E. Coli - 5 Total Coliforms 59	-Flushed south side of town. -Boil Water Advisory given by Medical Office of Health. -Three clean (0 Coliforms counts) sets on samples in a row. - Boil Water Advisory Rescinded	Three sets of clean samples taken on the distribution system Fire Hall 112 Raina Way KDH
December 31, 2008	Total Coliforms - 3	-Medical Officer of Health requested 3 clean samples for the distribution point where sample was taken	Three samples from the distribution point came back clean NGMC